SmartBrace[®] Design Guide







ASINZS 2069.0 - F22







Scope of this Design Guide

This Design Guide assists users to design interpret Table 8.18 within AS 1684.2—2021 to calculate the bracing capacity for F22 SmartBrace brace ply for most of the common structural arrangements in domestic construction.

The SmartFrame software in conjunction with AS 1684 provides tools for calculating the racking forces on buildings.

While specific details are given on suitable methods of developing racking resistance, the methods of providing adequate diaphragm support, overall anchorage against wind uplift and overall structural stability are outside the scope of this publication. Information on the above matters can be obtained from AS 1684 Residential timber-framed construction code or from a structural engineer experienced in timber construction.

Tilling Timber Pty Ltd has structural engineers on staff who can be contacted for advice on matters concerning the use of its engineered timber products in timber construction on the Techsupport Customer helpline on 1300 668 690 or at techsupport@tilling.com.au.

Basis of stated capacities

The information contained in this product brochure is current as at May 2023 and is based on data available to Tilling Timber Pty Ltd at the time of going to print.

The bracing capacities for F22 SmartBrace manufactured for Tilling Timber within this document are interpolated from Table 8.18 of AS 1684.2-2021, and have been confirmed with individual testing to ASTM E72 carried out at Universal Testing Facility Pty Ltd (UTF) in Dandenong South for alternative stud spacing's, where applicable.

AS 1684.2-2021 is a primary reference document in the NCC and is a therefore a "deemed to satisfy" solution.

Tilling Timber Pty Ltd has used its reasonable endeavours to ensure the accuracy and reliability of the information contained in this document and, to the extent permitted by law, will not be liable for any inaccuracies, omissions or errors in this information nor for any actions taken in reliance on this information.

Tilling Timber Pty Ltd reserves the right to change the information contained in this document without prior notice. It is important that you call the techsupport customer helpline on 1300 668 690 to confirm that you have the most up to date information available.

Copyright

Copyright of this publication remains the property of Tilling Timber Pty Ltd, and reproduction of the whole or part of this publication without written permission from Tilling Timber Pty Ltd is prohibited.

F22 SmartBrace properties

F22 SmartBrace brace ply is made from Chain of Custody Certified plantation Eucalypt veneers manufactured by Furida Wood Co. Ltd. The manufacturing is carried out under third party audited process control with in-factory testing in the factory's laboratory, and further third party testing of the Type A bond quality, F grade and formaldehyde emission at the University or Technology Sydney (UTS).



Compliance with process based quality control re-

quirements is third party audited by SAI- Global, and the audits, together with end product testing, is used as the basis for Product Certification by SAI-Global as a JAS-ANZ accredited Product Certification body.



JAS-ANZ stands for the government established "Joint Accreditation System of Australia and New Zealand" which exists as the peak organisation for accreditation of Product Certification.

Features

F22 SmartBrace is a new and innovative bracing product manufactured from plantation Eucalypt hardwoods from certified forests and is an economical replacement for tropical rainforest plywoods predominantly sourced from South East Asia, some with unknown provenance.

It is a strong and durable raw, H2s or H2 preservative treated engineered wood panel (can be post production treated to H3), a true High Performance hardwood plywood complying to AS/NZS 2269.

Applications

F22 SmartBrace is designed to resist horizontal racking forces applied to buildings such as cavity bracing in external wall frames in brick veneer construction, and to resist uplift in braced walled systems.

Ordering F22 SmartBrace

| F22 SmartBrace size | | Pieces | Area | Weight/ | Weight/ |
|---------------------|---------------|-------------|------------------|---------------|--------------|
| Length (mm) | Width (mm) | per pack | per pack (m²) | panel (kg) | pack (kg) |
| 2440 | 900 | 150 | 329.4 | 5.5 | 824 |
| 2440 | 1200 | 150 | 439.2 | 7.3 | 1098 |
| 2745 | 900 | 150 | 370.6 | 6.2 | 927 |
| 2745 | 1200 | 150 | 495.7 | 8.3 | 1236 |
| 3050 | 900 | 150 | 144.8 | 6.9 | 1029 |
| 3050 | 1200 | 150 | 549.0 | 9.2 | 1373 |

Timber framing

Timber wall frames should comply with government building regulations and where applicable AS 1684. Framing members should be minimum F5 stress grade and joint strength group or JD5 (seasoned). Stud spacing's should not exceed 600 mm centres for 1200 mm sheets and 450 mm centres for 900 mm sheets.

The resistance values in the enclosed tables are based upon fixing the sheeting to framing having a minimum joint strength of JD5. Where the timber framing is of joint strength of JD4, racking resistance for the F22 SmartBrace systems in this Design Guide may be increased by 12.5%.

It is essential for the bracing walls to be securely connected to the roof and sub-floor systems. Wind forces acting on the roof must be resisted and transferred to the ceiling diaphragm and through the walls to the sub-floor. The methods of connection are detailed in AS 1684, and include nail fixings, galvanised iron straps, framing anchors and bolts.

Weather Exposure

During normal weather conditions, SmartBrace may be exposed to the weather and subjected to wetting and drying. As the product is supplied in a moisture-conditioned state (seasoned), it is advisable to enclose the building as soon as possible after fixing the sheets. A maximum exposure period of three months is recommended.

SmartBrace is a wood panel product and therefore some dimensional movement may occur during extended periods of extremely high or low relative humidity.

Installation

Before installation SmartBrace panels should be checked for:

- 1. Correct panel grade and marking
- 2. Correct panel thickness
- 3. Any physical damage

F22 SmartBrace should be installed vertically with sheet ends fixed to the top and bottom plates. Support the vertical edges over studs. F22 SmartBrace like all wood based products is hygroscopic, meaning the panel will adjust to the equilibrium moisture content of its environment. To allow for small dimensional movement of the F22 SmartBrace panel, allow a 2 mm gap between sheets and raise the sheets 2 mm from the floor.

Uplift force may require additional fixings at the end of the bracing panel in accordance with AS 1684.

Fix sheets with 2.8 mm \emptyset x 30 mm flat head galvanised or corrosive resistant nail, the fastener head should NOT be driven into the sheet. When stressing the frame under high loads, the modes of failure are typically nail pull through, failure of the joint between the studs and plates or plate splitting. By staggering the nails, the latter failure is minimised since a common crack line is not induced in the plate.

Simplified bracing for non-cyclonic areas

Bracing walls are set at right angles to the windward walls. In accordance with AS 1684, they should be evenly distributed throughout each storey of the building. Bracing shall initially be placed in external walls, and where possible, at the corners of the building. Where bracing cannot be placed in external walls because of openings or similar situations, a structural diaphragm ceiling may be used to transfer racking forces to bracing walls that can support the loads.

Unless otherwise specified, sheet bracing walls shall be a minimum of 900 mm wide. Clause 8.3.6.5 of AS 1684.2 gives limited exceptions to this, and these exceptions are described as part of the capacity diagrams within this Design Guide.

Total bracing requirements for each 'area of elevation' of the windward walls can be obtained from the SmartFrame software suite or alternatively AS 1684 Table 8.2. Ensure that the minimum bracing unit requirements for the external walls are satisfied. The additional bracing units can then be evenly distributed throughout the external and internal walls.

For the number of F22 SmartBrace sheets, divide the bracing unit requirements by the Design Capacity per sheet width in this Design Guide. Where the building elevation contains combinations of pitched roofs, gable or skillion ends, or upper or lower storeys, the 'area of elevation' of each section should be calculated separately to determine the total bracing unit requirements.

Brick veneer construction

F22 SmartBrace is ideal for use as cavity bracing in brick veneer stud construction. Brick wall ties must be the face-fixed type and comply with AS 2699 - Wall Ties for Masonry Construction. The ties should be nailed through the F22 SmartBrace into the narrow face of the studs.

Wall cavities should be kept clear of obstructions and the wall ties sloped downwards, away from the frame and bracing.



When constructing boxed eaves, the inner ends of soffit bearers or sprockets should not penetrate through the structural sheet bracing. Hangers suspended from the top wall plate or rafters may support the ends.

Standard fasteners

The racking capacities of the systems in this Design Guide are based upon hand driven 2.8 Φ x 30 mm flathead structural clouts or connector nail, with alternative power nail* options listed below.

Fastener edge distances along top and bottom plates and edge studs should be a minimum of 15 mm and 7 mm where panels are fixed to internal framing.

The spacing for staples are two thirds (fastener spacing multiplied by 0.66) of those shown for nails or screws.

| Hand driven nails | Flathead structural clouts or connector nail 2.8 Φ x 30 mm | | | | | | |
|----------------------|---|------------------|-----------------------------------|--------------|--|-----------|--|
| | | Coil Na | ailer | Nails | | | |
| | Brand | Nailer code | Description | Nail Code | Size | Collation | |
| | BeA | 45800-3 | | 45041 | FAP32 x 2.5 mm $oldsymbol{\phi}$ EG Helical twist (clout nail) | Plastic | |
| | | | 22 mm to 65 mm pails | 45144 | FAP32 V5 2.9 mm Φ HDG screw (Clout nail) | Plastic | |
| Power driven nails * | | | | 45042 | FAP38 V5 2.5 mm EG Φ Helical twist (clout nail) | Plastic | |
| | | 43500 | ANDCO Air anabar pailar | 43506 | 36.5 x 3.3 mm $oldsymbol{\phi}$ Anchor nails | Paper | |
| | | | ANROU AIT anchor haller | 43512 | 40x 4.0 mm Φ Anchor nails | Paper | |
| | Paslode | B40001 | Impulse CoilMaster IM50S | B40027 | 32 x 2.7 mm Φ (Hot Dip Galvanised) | 0° Coil | |
| | | B21094 or B21095 | CNW 57 or CNW 70.1 Coil Nailer | B25115 | 32 x 2.7 mm Φ (Hot Dip Galvanised) | 15° Coil | |
| | Bostitch | N80CB-1ML | Coil nailer 80 mm Max | AC45R250-GAL | 45 x 2.5 mm ϕ galvanised | 15° Coil | |
| | DuoFast | D40010 or D40030 | CNP 50 or 65.1 Coil Nailer | D41810 | 32 x 2.7 mm $arPhi$ (Hot Dip Galvanised) | 0° Coil | |
| | Senco | TBC5700 Aico A | | AC45R250-GAL | 45 x 2.5 mm ϕ galvanised | 15° Coil | |
| | | | Aico A57 Coil nailer | YA45252R | AC45R250-GAL HDG Ring Shank 45 x 2.5 mm Φ | 15° Coil | |

Standard fasteners (cont'd)

Notes:

- The above power driven nail sizes have been provided by the respective manufacturers to Tilling Timber Pty Ltd as offering an equivalent capacity as the hand driven 2.8 Φ x 30 mm Flathead structural clouts or connector nail and while their performance with SmartBrace has not been the subject of individual testing, experience and engineering judgement has been exercised
- 2. This list is offering advice only, and does not preclude any other fastener being used that can be demonstrated to exhibit equivalent capacity as the 2.8 ϕ x 30 mm Flathead structural clouts or connector nail
- 3. This list was correct at the time of publication, so users may need to refer to the respective manufacturer if the listed option is no longer available.

Wall capacity and height modification

The racking capacities of the systems in this Design Guide are based upon a wall height of 2700. For walls of different heights, the capacity shall be multiplied by the value given below:

Bracing wall capacity/height modifier

| Wall height (mm) | Multiplier |
|------------------|------------|
| 2400 | 1.12 |
| 2700 | 1.00 |
| 3000 | 0.90 |
| 3300 | 0.80 |
| 3600 | 0.75 |
| 3900 | 0.70 |
| 4200 | 0.64 |

Penetrations through SmartBrace panels

Should it be necessary to penetrate the F22 SmartBrace for plumbing or electrical installations, keep the penetrations to a minimum and locate them towards the centre of the sheet. Holes should always be neatly cut and the corners rounded.

Areas within 300 mm of corners should be avoided. Large service pipe penetrations of up to but not exceeding 150 mm diameter are limited to one hole per sheet. Small diameter service pipe penetrations of approximately 30 mm diameter should be drilled and not exceed four holes per sheet. Holes should be placed as close as possible to the sheet centre.



Sawing, drilling and shaping

F22 SmartBrace can be sawn and shaped like solid wood in any

way with standard wood working tools in a well ventilated open area to avoid breathing wood dust. If hand held equipment without suction is used, a protective face mask should be worn.

It is recommended that carbide tipped tools are used to provide the neatest cut without damaging the edge of the F22 SmartBrace panel. Conventional hand or power drilling tools are suitable for providing penetrations.

Fixing of bottom plates

The lateral force effects due to wind and earthquakes are resisted by bracing walls results in two separate methods of action on bracing elements. The first action is an in-plane sliding force transferred to the bottom plate. Sufficient fixings of the bottom plate to the sub-floor/slab must be designed to resist this in-plane 'shear' force.

The second action induces rotation or overturning effects which tie rods extending from the top plate to the sub-floor and located at each end of bracing wall provide excellent resistance. For bracing elements requiring lower resistance, nominal connection of the bottom plate to the sub-floor/slab can overcome these overturning forces. Nominal fixings (minimum fixings) are defined in clause 9.5 of AS 1684.2 - 2021, but for bottom plates the requirements for nominal fixing is shown below.

| Wind classification | Concrete slab subfloor | Bottom plates ≤ 38 mm to joists | Bottom plates 38 to 50 mm to joists |
|--|---|---|---|
| N1, N2, N3, N4 and C1, C2 and C3 | 75 mm masonry nails, screws or bolts and 1200 mm max centres | 2/3.05Ø x 75 mm at a max of 600 mm centres | 2/3.05Ø x 90 mm at a max of 600 mm centres |

1. Bottom plate fixing up to 3.4 kN/m systems

No additional bottom plate fixing other than nominal bottom plate fixing as specified in AS 1684 is required for bracing systems with resistance less than 3.4 kN/m. However, if the 3.4 kN/m system is used on both sides of a frame to double the bracing capacity in that section of wall, then the bottom plate fixing will need to be upgraded to be equivalent for a 6.4 kN/m system.

2. Bottom plate fixing for 5.3, 6.0 and 6.4 kN/m systems

The minimum fixing requirement for 5.3, 6.0 and 6.4 kN/m bracing capacity systems is 13 kN tie down every 1200 mm along the bottom plate or equivalent.



A looped 30 mm x 1 mm width galvanised looped strap as shown above is equivalent to 13 kN tie down.

3. Bolt fixing of bottom plates

The tie down capacity of some bolts through a range of timber joint strengths are presented below. If the bolts are used in concrete slabs they must be appropriately embedded. For lower capacity bolted joints the resistance can be obtained by reducing the spacing of the bolts.

| Joist strength group | J2 | J3 | J4 | JD4 | JD5 | JD6 |
|----------------------|----------------|----|----|-----|-----|-----|
| Bolt diameter (mm) | Capacity in kN | | | | | |
| 10 | 18 | 18 | 18 | 15 | 12 | 9 |
| 12 | 27 | 27 | 26 | 20 | 16 | 12 |
| 16 | 50 | 50 | 46 | 35 | 28 | 21 |

Uplift Capacities



Bottom plate connection to floor substrate as per AS 1684. Limited examples are included in this Design Guide

Characteristic uplift resistance

| Panel type | Uplift per 900 mm panel (kN) | | |
|-------------------|------------------------------|--|--|
| Type (g) | 4.0 | | |
| Type (h) Method B | 11.0 | | |

Storage and handling

Correct storage and handling of F22 SmartBrace is essential to ensure problem free installation and to guarantee bracing resistance capacities for each panel as specified in this Design Guide.

- 1. Store SmartBrace panels horizontally on squared bearers of even height
- 2. Should packs be stacked on top of each other, bearers should be aligned vertically



3. Bearer spacing is to be as per the table below.

| Thickness (mm) | Width (mm) | Length (mm) | No of bearers (pcs) |
|-------------------|------------|-------------|------------------------|
| | | 2440 | 5 |
| | 460 | 2745 | 5 |
| | | 3050 | 6 |
| 4 | 900 | 2440 | 5 |
| | | 2745 | 5 |
| | | 3050 | 6 |
| | | 2440 | 5 |
| | 1200 | 2745 | 5 |
| | | 3050 | 6 |

4. SmartBrace should be stored protected from direct exposure to the weather in a well ventilated area



5. SmartBrace panels should not be stored in direct contact with the ground



6. If the panels are to be moved by mechanical lifting equipment such as fork lifts, the bearers must be of sufficient height to allow forks to slide under the full pack without causing damage to panels.

F22 SmartBrace Systems

The allowable racking resistance of F22 SmartBrace Systems for frames sheathed on one side only, are as follows. The resistance values may be doubled for frames sheathed on both sides provided that the hold down requirements of the bottom plate are also doubled AND the bottom plate checked to ensure satisfactory bending capacity.









Type (g) system 3.0 kN/m

1. Fastener centres

- 150 mm for top and bottom plates
- 150 mm for vertical edges
- 300 mm for intermediate studs
- 2. For both 450 and 600 mm stud spacing
- 3. Minimum section bracing of 900 mm to achieve the above capacity. For panel length of 600 mm, the bracing capacity shall be 50% (½) of that for a 900 mm panel. For panel length between 600 mm and 900 mm, the bracing capacity may be determined by multiplying the above capacity by 0.5 for 600 mm long varying linearly to 1.0 for 900 mm.
- 4. Minimum Joint strength JD5. If JD4 framing is used, increase capacity by 12.5 %
- 5. Requires a 2 mm expansion gap around perimeter of every panel.
- 6. For wall height greater than 2700 mm, the reduction factor on page 4 of the Design Guide shall be applied.

Type (h) system Method A 5.6 kN/m

NOTES:

1. Fastener centres

- 150 mm for top and bottom plates
 - 150 mm for vertical edges
- 300 mm for intermediate studs
- 2. For both 450 and 600 mm stud spacing
- 3. Minimum section bracing of 600 mm.
- 4. Minimum Joint strength JD5. If JD framing is used, increase capacity by 12.5 %
- 5. Requires a 2 mm expansion gap around perimeter of every panel
- 6. M12 rods shall be used at each end of the sheathed section top plate to bottom plate /floor frame
- 7. Requires 13 kN capacity connection at a maximum of 1200 mm centres (see examples methods in this Design Guide)
- For wall height greater than 2700 mm, the reduction factor on page 4 of the Design Guide shall be applied.

Racking setup - Type (h) Table 8.18 of AS 1684.2 Method B



Type (h) system Method B 5.2 kN/m

NOTES:

- 1. Fastener centres
 - 50 mm for top and bottom plates and any horizontal butt joints
 - 150 mm for vertical edges
 - 300 mm for intermediate studs
 - 2. For both 450 and 600 mm stud spacing
 - 3. Minimum section bracing of 900 mm.
 - 4. Minimum Joint strength JD5. If JD4 framing is used, increase capacity by 12.5 %
 - 5. Requires a 2 mm expansion gap around perimeter of every panel.
 - Requires 13 kN capacity connection at each end and intermediately at a maximum of 1200 mm centres (see examples methods in this Design Guide)
 - 7. For wall height greater than 2700 mm, the reduction factor on page 4 of the Design Guide shall be applied.

450 mm Short Wall 1.9 kN/m

NOTES:

- 1. Fastener centres
 - 80 mm for top and bottom plates
 - 150 mm for vertical edges
 - 2. For 450 mm stud spacing
 - 3. M10 x 70 coach screws in each corner of sheathed panel

or

M12 rod at each end of the

sheathed section

- 2. Minimum Joint strength JD4. If JD5 framing, or softwood framing from an unknown specie is used, reduce capacity by 12.5 %
- 3. Requires a 2 mm expansion gap around perimeter of every panel
- 4. For wall height greater than 2700 mm, the reduction factor on page 4 of the Design Guide shall be applied

Racking setup - 450 mm wall





Head Office Victoria

31-45 Orchard Street, Kilsyth Vic 3137 email: sales@tilling.com.au Phone +61 3 9725 0222

Fax +61 3 9725 3045

New South Wales

109 Kurrajong Avenue, Mt Druitt, NSW 2770 email: nswsales@tilling.com.au Phone +61 2 9677 2600 Fax +61 2 9677 2500

Queensland

84 Magnesium Drive, Crestmead QLD 4132 email: qldsales@tilling.com.au Phone +61 7 3440 5400 Fax +61 7 3440 5444

Western Australia

10 Cartwright Drive Forrestdale WA 6112 email: wasales@tilling.com.au Phone +61 8 9399 1609 Fax +61 8 9399 1065

South Australia

5-9 Woomera Ave Edinburgh SA 5111

email: sasales@tilling.com.au Phone +61 8 8345 1966 Fax +61 8 8345 1977

Sales 1800 33 77 03

Technical support 1300 66 86 90

© 2023 Tilling Timber Pty Ltd ABN 92 004 621 121 Date of publication June 2023 SmartFrame is a Registered Trademark of Tilling Timber

